

§ 95.01-1

Subpart 95.15—Carbon Dioxide Extinguishing Systems, Details

- 95.15-1 Application.
- 95.15-5 Quantity, pipe sizes, and discharge rates.
- 95.15-10 Controls.
- 95.15-15 Piping.
- 95.15-20 Carbon dioxide storage.
- 95.15-25 Discharge outlets.
- 95.15-30 Alarms.
- 95.15-35 Enclosure openings.
- 95.15-40 Pressure relief.
- 95.15-90 Installations contracted for prior to November 19, 1952.

Subpart 95.17—Foam Extinguishing Systems, Details

- 95.17-1 Application.
- 95.17-5 Quantity of foam required.
- 95.17-10 Controls.
- 95.17-15 Piping.
- 95.17-20 Discharge outlets.
- 95.17-25 Additional protection required.
- 95.17-90 Installations contracted for prior to November 19, 1952.

Subpart 95.30—Automatic Sprinkler Systems, Details

- 95.30-1 Application.

Subpart 95.50—Hand Portable Fire Extinguishers and Semiportable Fire Extinguishing Systems, Arrangements and Details

- 95.50-1 Application.
- 95.50-5 Classification.
- 95.50-10 Location.
- 95.50-15 Spare charges.
- 95.50-20 Semiportable fire extinguishers.
- 95.50-90 Vessels contracted for prior to November 19, 1952.

Subpart 95.60—Fire Axes

- 95.60-1 Application.
- 95.60-5 Number required.
- 95.60-10 Location.

AUTHORITY: 46 U.S.C. 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; Department of Homeland Security Delegation No. 0170.1.

SOURCE: CGFR 65-50, 30 FR 17001, Dec. 30, 1965, unless otherwise noted.

Subpart 95.01—Application

§ 95.01-1 General.

(a) The provisions of this part shall apply to all vessels except as specifically noted in this part.

46 CFR Ch. I (10-1-07 Edition)

§ 95.01-2 Incorporation by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register in accordance with 5 U.S.C. 552(a). To enforce any edition other than that specified in paragraph (b) of this section, the Coast Guard must publish notice of change in the FEDERAL REGISTER and make the material available to the public. All approved material is on file at the U.S. Coast Guard, Office of Design and Engineering Standards (G-MSE), 2100 Second Street SW., Washington, DC 20593-0001 or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. All material is available from the sources indicated in paragraph (b) of this section.

(b) The material approved for incorporation by reference in this part and the sections affected are:

American Society for Testing and Materials (ASTM)

100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM F 1121-87 (1993), Standard Specification for International Shore Connections for Marine Fire Applications—95.10-10

National Fire Protection Association (NFPA)

1 Batterymarch Park, Quincy, MA 02269-9101.
NFPA 13-1996, Standard for the Installation of Sprinkler Systems—95.30-1

[CGD 88-032, 56 FR 35825, July 29, 1991, as amended by CGD 95-072, 60 FR 50464, Sept. 29, 1995; CGD 96-041, 61 FR 50729, Sept. 27, 1996; CGD 97-057, 62 FR 51045, Sept. 30, 1997; CGD 95-028, 62 FR 51206, Sept. 30, 1997; USCG 1999-5151, 64 FR 67181, Dec. 1, 1999]

§ 95.01-5 Equipment installed but not required.

(a) Where fire detecting or extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation shall meet the requirements of this part.